

REPORT NO. NADC-79033-60

LEVEL II

12



**THERMAL CONDUCTION EFFECTS IN HUMAN SKIN:
I. EXPERIMENTAL DATA ACQUISITION**

M.A. Chianta, A.M. Stoll and J.R. Piergallini
Aircraft and Crew Systems Technology Directorate
NAVAL AIR DEVELOPMENT CENTER
Warminster, Pennsylvania 18974

15 JANUARY 1979

PHASE REPORT
AIRTASK NO. WF51-523-000
Program Element 62758N


INTERAGENCY AGREEMENT NO. CPSC IAG-77-0091

APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

Prepared for
NAVAL AIR SYSTEMS COMMAND
Department of the Navy
Washington, D.C. 20361

and

U.S. CONSUMER PRODUCT SAFETY COMMISSION
Washington, D.C. 20207



AD A068479

DDC FILE COPY

79 05 09 004

NOTICES

REPORT NUMBERING SYSTEM - The numbering of technical project reports issued by the Naval Air Development Center is arranged for specific identification purposes. Each number consists of the Center acronym, the calendar year in which the number was assigned, the sequence number of the report within the specific calendar year, and the official 2-digit correspondence code of the Command Office or the Functional Directorate responsible for the report. For example: Report No. NADC-78015-20 indicates the fifteenth Center report for the year 1978, and prepared by the Systems Directorate. The numerical codes are as follows:

CODE	OFFICE OR DIRECTORATE
00	Commander, Naval Air Development Center
01	Technical Director, Naval Air Development Center
02	Comptroller
10	Directorate Command Projects
20	Systems Directorate
30	Sensors & Avionics Technology Directorate
40	Communication & Navigation Technology Directorate
50	Software Computer Directorate
60	Aircraft & Crew Systems Technology Directorate
70	Planning Assessment Resources
80	Engineering Support Group

PRODUCT ENDORSEMENT - The discussion or instructions concerning commercial products herein do not constitute an endorsement by the Government nor do they convey or imply the license or right to use such products.

APPROVED BY: Edward J. Starn DATE: 3/15/79

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER (14) NADC-79033-60	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER (9)
4. TITLE (and Subtitle) (6) Thermal Conduction Effects in Human Skin. I. Experimental Data Acquisition		5. TYPE OF REPORT & PERIOD COVERED Phase Report
6. PERFORMING ORG. REPORT NUMBER		7. CONTRACT OR GRANT NUMBER(s)
8. AUTHOR (10) M. A. Chianta, A. M. Stoll J. R. Piergallini		(15) CPSC-77-0091
9. PERFORMING ORGANIZATION NAME AND ADDRESS Aircraft & Crew Systems Technology Directorate Naval Air Development Center Warminster, PA 18974		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS AirTask WF51-523-000, P.E. 62758N; Interagency Agree- ment CPSC TAG-77-0091
11. CONTROLLING OFFICE NAME AND ADDRESS Refer to Block 18		12. REPORT DATE (11) 15 January 1979
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) (16) F51523		13. NUMBER OF PAGES 14
(17) WF51523000		15. SECURITY CLASS. (of this report) UNCLASSIFIED
16. DISTRIBUTION STATEMENT (of this Report) APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES Naval Air Systems Command U.S. Consumer Product Safety Commission Department of the Navy Washington, D.C. 20207 Washington, D.C. 20361		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Safe material temperatures Pain threshold temperatures Thermal conduction in skin		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) To determine the maximum permissible temperature any material may attain without causing pain or burn on contact with bare skin, over 2000 observations were made of pain threshold during contact with materials at elevated temperatures. Six materials were used representing the full range of thermal properties of good conductors to good insulators. Initial specimen and skin temperatures, interface (material-skin) temperatures throughout contact, and time to pain threshold were noted. An orderly relationship was found between		

DD FORM 1 JAN 73 1473

EDITION OF 1 NOV 65 IS OBSOLETE
S/N 0102-LF-014-6601

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

393 532

JOL

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

20. ^a pain threshold and material temperature, either longer exposures or higher specimen temperatures being associated with better insulative properties. Variations in thickness of the epidermis affect these times and temperatures so that families of curves are generated from data obtained at sites of increasing thickness. On the basis of the relationship demonstrated between pain sensation and thermal properties the material temperature which will cause a blister on contact may be predicted.

ACCESSION NO.	
DTIC	UNCLASSIFIED <input checked="" type="checkbox"/>
DDC	DDC SERVICE <input type="checkbox"/>
UNANNOUNCED	<input type="checkbox"/>
JUSTIFICATION	
BY	
DISTRIBUTION/AVAILABILITY STATE	
GND. AVAIL. NO./BY SPECIAL	
A	

S/N 0102- LF-014-6601

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

TABLE OF CONTENTS

	Page
INTRODUCTION	2
METHOD	2
RESULTS AND DISCUSSION	7
CONCLUSIONS	14
REFERENCES	14
ACKNOWLEDGMENT	14
LIST OF FIGURES	1
LIST OF TABLES	1

FIGURES

1	Radiometric measurement of initial temperature of specimen and skin site	4
2	Interface temperature recorded during contact to pain threshold end point	5
3	Threshold pain and blister parameters, tolerance time vs energy absorption rate	6
4	Pain threshold time vs material temperature, three fingers of same hand, one material	9
5	Pain threshold time vs material temperature, ring finger of four subjects, one material	10
6	Pain threshold time vs material temperature finger pad and back of same finger, one material	11
7	Variations in time to pain threshold at given temperatures due to differences in thermal properties of materials	13

TABLE

I	Thermal properties of experimental materials	8
---	--	---

INTRODUCTION Excessive heating occurs in cockpit materials such as display and control consoles due to proliferation of avionics and in fuselage walls in VSTOL aircraft due to ducting of hot gases past the cockpit. The high temperatures generated constitute a thermal hazard to the crewman, subjecting him to the risk of pain and burns on contact between bare skin and materials. The present study was undertaken to eliminate such hazard by enabling preselection of thermally safe construction materials during the engineering design phase. It establishes the biophysical data base and engineering guidelines for prediction of the highest permissible temperature specific materials may attain without causing pain or burn on contact.

METHOD The method for accomplishing this prediction entails four steps: (Step 1) experimental determination of pain threshold time at various temperatures of materials ranging in thermal properties from good conductors (metals) to good insulators (e.g., Masonite); (Step 2) calculation (from relationships obtained in earlier work) of time to minimal blister for each of these materials; (Step 3) extrapolation of the calculated data to the material temperature which will produce a blister on 0.3 sec contact with bare skin of minimal epidermal thickness, and (Step 4) establishment of curves for all materials studied relating material temperature, contact time to pain and to blister and thermal inertia (i.e., the product of thermal conductivity k , density ρ , and specific heat c).

In the first step it was necessary to establish, before collection of experimental data, that the subjects, two females and two males, had normal pain thresholds. The pricking pain threshold of each subject was measured in a standard manner (1) by exposing the volar surface of the forearm (a site chosen because

it represents a uniformly thin area in the epidermis (2) to a radiant energy source, a commercially available Dolorimeter in which the shutter was modified to provide a truly square-wave pulse over a small area (1.3 cm diameter). The radiant flux required to produce the pain threshold in 3 seconds in all subjects was $300 \pm 8\%$ mcal/cm²sec at an initial skin temperature of 32.5°C, the normal value at this initial temperature (2). In a similar manner pain threshold measurements were made on each of the three "test" fingers of each subject for use in estimating the thickness of the epidermis (3) in these areas.

In the experimental procedure six representative materials were heated to a given temperature (45°C to 195°C); the initial skin temperature of the finger, maintained at 32.5 \pm 0.5°C, was measured radiometrically by the subject just before contact with the heated material; simultaneously, the temperature of the sample was measured radiometrically on a blackened corner of the specimen by an operator; contact was made at time zero and maintained until pain threshold was reached; the interface temperature was recorded throughout by a fine wire thermocouple attached to the finger (Figures 1, and 2).

In the second step pain threshold times measured in each material are converted to time to threshold blister on the basis of a relationship previously established (4) wherein the pain and blister parameters are virtually parallel (Figure 3). The procedure then consists of multiplying time to pain threshold by a factor of 2.5 to obtain time to threshold blister.

The third step required extrapolation of calculated blister time data to the material temperature which will produce a threshold blister instantaneously. This extrapolation cannot be made directly from the experimental curve because it tends to become asymptotic. Therefore, the calculated blister times were




FIGURE 1 - Radiometric measurement of initial temperature of specimen and skin site.




FIGURE 2 - Interface temperature recorded during contact to pain threshold end point.




FIGURE 3 - Threshold pain and blister parameters, tolerance time vs energy absorption rate.

converted to reciprocals and this curve extrapolated to the material temperature corresponding to a contact time of 0.3 second, allowing 0.2 second for reaction time and an additional 0.1 second to ensure good contact.

Step four concerns the application of the observed data to selection of safe materials.

RESULTS AND DISCUSSION In all, over 2000 observations were made on the skin sites of four normal subjects exposed to six heated materials representing a wide range of thermal properties as shown in Table I.

In any one series of exposures, i.e., one material at different levels of temperature, the pain threshold end point was quite precisely identified so that, in most instances, smooth curves with very little scatter of individual points resulted (Figures 4, 5 and 6). However, the variation in end point from day to day within any one individual was sometimes as much as $\pm 10\%$ as might be expected with this method (1). Thus, the overall accuracy for one individual became about $\pm 6.5\%$.

The data on any one subject in contact with a specific material yielded a different curve for each of three fingers of the same hand because of differences in the thickness of the epidermal layer (Figure 4). Since the effective depth of the pain receptors lies in the dermal layer, an increased thickness of the epidermis lengthens the heat transfer pathway to the receptors, changes the total conductivity and increases the time to pain perception. Figure 5 shows similar data for all four subjects using the right ring finger of each. At the longer pain threshold times there is little difference in the specimen temperature required to produce the end point, but at the shorter times, where the insulative properties of the epidermal layer exert the greatest effect, the difference in specimen temperature for the same pain threshold time between the

T A B L E I

THERMAL PROPERTIES OF EXPERIMENTAL MATERIALS

Material	$k \times 10^{-3}$ $\frac{\text{cal}}{\text{sec}^\circ\text{Ccm}}$	ρ $\frac{\text{gm}}{\text{cc}}$	c $\frac{\text{cal}}{\text{gm}^\circ\text{C}}$	$k\rho c \times 10^{-3}$ $\frac{\text{cal}^2}{\text{cm}^4 \text{ }^\circ\text{C}^2 \text{ sec}}$	$\frac{1}{\sqrt{k\rho c}}$
Aluminum	370	2.70	0.23	230	2.09
Steel	103	7.84	0.067	54	4.30
Hercuvit	4	2.50	0.20	2.00	22.36
Glass	1.94	2.50	0.20	0.97	32.11
Teflon	0.58	2.15	0.25	0.31	56.64
Masonite	0.413	1.00	0.40	0.165	77.80

k = thermal conductivity, ρ = density,

c = specific heat, $k\rho c$ = thermal inertia




FIGURE 4 - Pain threshold time vs material temperature, three fingers of same hand, one material.




FIGURE 5 - Pain threshold time vs material temperature, ring finger of four subjects, one material.




FIGURE 6 - Pain threshold time vs material temperature finger pad and back of same finger, one material.

subjects having the thinnest and the thickest epidermis is significant, in this instance 55°C at the 1 second level. To further illustrate the effect of epidermal thickness, data from exposures of the finger pad and the back of the same finger are shown in Figure 6.

Under this experimental condition there can be no question of individual differences in conductivity or other thermal properties accounting for the increase in time or material temperature. Again it is seen that there is a significant difference in material temperature at a given contact time, entirely attributable to difference in epidermal thickness. Therefore, epidermal thickness estimates were obtained on all test sites by measurements of pain threshold energy inputs and suitable equations for heat flow in a two-layer system (3). These measurements enabled a systematic treatment of the data with respect to different materials as shown by a typical set of values (Fig. 7).

Here it is seen that at a given epidermal thickness and contact time, the material temperature at pain threshold (T_{mPT}) varied widely, the good conductors producing this end point at much lower temperatures than the good insulators, and materials of intermediate thermal properties lined up between these extremes in the order of their relative thermal inertias. The difference in T_{mPT} between the extremes represented by aluminum and Masonite is seen to be very large at 1 sec contact time, i.e., 70°C ($142^{\circ} - 72^{\circ}$); at 5 sec contact time this difference is reduced to 31° ($85^{\circ} - 54^{\circ}$); still a very appreciable amount. Similar families of curves can be drawn for different epidermal thicknesses. These curves shift to higher temperatures at greater thicknesses and lower temperatures at lesser thicknesses but always arranged in the same relative positions with respect to the thermal properties of the materials. Such differences across the whole spectrum of properties points up the thermal safety advantages to be gained by careful selection of materials designed for use in specific applications.




FIGURE 7 - Variations in time to pain threshold at given temperatures due to differences in thermal properties of materials.

CONCLUSIONS The results reveal an orderly relationship between pain threshold time and the temperature of each material, either long exposures or higher specimen temperatures being associated with better insulative properties. Variations in the thickness of the epidermis further affect these times and temperatures, so that families of curves are generated from data obtained at sites of increasing thickness.

It is concluded that these data are suitable for use in predicting material temperatures which will cause blisters following contact with the bare skin.

REFERENCES

1. Hardy, J.D., H.G. Wolf and H. Goodell, Pain Sensations and Reactions. Baltimore: Williams and Wilkins 1952 pp 80-85.
2. Stoll, A.M. and L.C. Greene, Relationship between pain and tissue damage due to thermal radiation. J. Appl. Physiol. 14:373-382, 1959.
3. Stoll, A.M., Thermal properties of human skin related to nondestructive measurement of epidermal thickness. J. Invest. Derm. 69:328-332, 1977.
4. Stoll, A.M. and M.A. Chianta, Method and rating system for evaluation of thermal protection. Aerospace Med. 40:1232-1238, 1969.

Work supported by the Naval Air Systems Command and the U.S. Consumer Product Safety Commission. The voluntary informed consent of the participating subjects was obtained as requested by existing U.S. Navy regulations.

ACKNOWLEDGMENT The authors are grateful to Mr. Dom Zaccaria for his excellent technical assistance.

D I S T R I B U T I O N L I S T (C o n t ' d)

	<u>No. of Copies</u>
NASA-Lewis, Cleveland, OH	1
NASA-Ames, Moffett Field, CA	1
NASA Scientific & Tech. Info. Facility, College Park, MD . . .	5
(3 for retention)	
(1 for S-AK/DL)	
(1 for NASA Rep.)	
Library of Congress, Washington, DC	2
(1 for Bibliographies Section)	
(1 for Science & Tech. Div.)	
HQ, Naval Material Command (034-D), Washington, DC	1
COMOPTEVFOR	1